11kV Trench 1.2m x 1.5m deep

TXR fiber/AC/DC

trench from battery and SCADA

33kV Trench 1.2m x 1.5m deep

AC/DC Trench

No.	REVISION	DATE	BY	CHK	PSD	APP
A	ISSUED AS FINAL DESIGN REVIEW	28-08-15	HC	RN	RN	RN

DRAWN	H.CHAN	28-08-15
CHECKED		
CHIEF DRAUGHTSMAN		
ENGINEER		
HOD	R.NARAYAN	28-08-15

FIJI ELECTRICITY AUTHORITY

MOMI SUBSTATION

11/33kV SUBSTATION TRENCH LAYOUT

DESIGN DRAWING FOR TENDER PURPOSES

DRAWING NUMBER *				REVISION
A3	XX	XXXX	XX	A
SCALE		CAD FILENAME		
N.T.S		_		

* DRAWING NUMBERS HAVE BEEN ASSIGNED FOR DESIGN AND CONSTRUCTION PURPOSES ONLY AND ARE SPECIFIC TO THIS PROJECT. UPON COMPLETION OF CONSTRUCTION, ASBUILT DRAWING NUMBERS SHALL BE ASSIGNED IN COORDINATION WITH THE EXISTING DRAWINGS FOR THIS FACILITY, AS PER FEA's DOCUMENTATION STANDARDS & ARCHIVING PROTOCOLS.