

# NOTICE TO TENDERERS



**MWH**<sup>®</sup>

**BUILDING A BETTER WORLD**

---

**Number Five**

**Date:** 25 August 2016

**Reference:** 80507610

**Client** Fiji Electricity Authority

MWH New Zealand Ltd

**Project** Wailoa Power Station Generator Rehabilitation  
Tender No. MR58/2016

---

1. Please find attached responses to the following questions raised by bidders for the above project:-
- 

Q1. Are alternative vibration and partial discharge monitoring systems permitted?

A1. Alternative partial discharge monitoring systems to the IRIS system specified would not be accepted.

Alternative vibration monitoring systems to the VibrosystM system specified would be considered provided that they have equal or better functionality to that specified and have demonstrated support within the Australasia/Pacific region. Full details of any alternative including a feature by feature comparison and reference sites within Australasia shall be provided with the bid.