FIJI ELECTRICITY AUTHORITY



TENDER SPECIFICATIONS TENDER

TENDER NO: MR 11/2017

Purchase of Waste Oil and Removal of HFO Sludge from FEA power stations

Submission of Tender

<u>Two (2) hard copies</u> of the tender bids in sealed envelope shall be deposited in the tender box located at the Supply Chain Office at the FEA Head Office, 2 Marlow Street, Suva, Fiji.

Courier charges for delivery of Tender Document must be paid by the bidders.

This tender closes at 25/01/2017

Site Visit: At any time convenient before the closing date. Location – FEA – Kinoya Depot (visits to other sites can also be arranged upon request)

Each tender shall be sealed in an envelope with:

The envelope bearing only the following marking:

<u>Tender- MR 11/2017 – Purchase of Waste Oil and Removal of HFO Sludge from FEA power</u> stations

The Secretary, Tender Committee
Fiji Electricity Authority
Supply Chain Office
Private Mail Bag, Suva

It must also indicate the name and address of the tenderer on the reverse of the envelope.

All late tenders, unmarked Envelopes and envelopes without bidder's name and address on the reverse of the envelope. (Bids via e-mail or fax will not be considered).

For further information or clarification please contact our Supply Chain Office on phone (+679) 3224360 or (+679) 9991587.

Purchase of Waste Oil and Removal of HFO Sludge from FEA power stations

FEA invites tenders for the purchase of waste oil and removal of sludge from the following power stations:

Sites:

- 1. Nadi Power Station
- 2. Sigatoka Power Station
- 3. Qeleloa Power Station
- 4. Rakiraki Power Station
- 5. Deuba Power Station
- 6. Korovou Power Station
- 7. Labasa (Cawaira) Power Station
- 8. Rokobili Power Station
- 9. Savusavu Power Station
- 10. Taveuni (Waiyevo) Power Station
- 11. Vuda Power Station Pernix
- 12. Kinoya Power Station Pernix
- 13. Levuka power station

Scope of works

- a. The contractor will pump existing waste oil on site into their tanks.
- b. The contractor will remove sludge from HFO sites on a weekly basis:
 - 1. Kinoya 8000-10000 liters of sludge per week
 - 2. Vuda 4000-6000 liters of sludge per week
- c. The contractor will be responsible for checks, cleaning and pumping out oil and water form interceptors located on various sites on a routine basis. The time interval between each cleanup may vary hence FEA team on ground may advise contractor as to when a cleanup is necessary.
- d. The contractor will must ensure that the pumping process complies with the Occupational Health Safety and Environment (OHSE) requirements at all times.
- e. The contractor must ensure that it has all specialized equipment and tools utilized in pumping out the waste oil and such equipment must be approved and recommended by the Department of Environment.
- f. The contractor shall commence pumping out procedure without any disruptions or disturbance to FEA's daily operations.
- g. The contactor shall comply with all Health and Safety requirements applicable and enforce it with relation to the pumping process
- h. The contractor shall be responsible for all remedial works as a result of any oil spillage during the transfer process
- i. The contractor must have a valid permit/license from the Department of Environment to pump out the waste oil and manage HFO sludge.

Transport/Tools/Equipment

- 1. The contractor will be responsible for the training of its staff who will be responsible for pumping out waste oil and HFO sludge from various sites.
- 2. The contractor will be solely responsible for providing transportation, tools and all applicable equipment to and from the site involved.
- 3. The contractor will be responsible for supplying all necessary required protective clothing and equipment which are relevant to pumping out waste oil and removing sludge.

RK: 13/01/2017



FIJI ELECTRICITY AUTHORITY

Purchase of Waste Oil and Removal of HFO Sludge from FEA power stations

Item	ITEM DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	Purchase of waste oil - per liter		
2	Removal of Sludge (HFO) – per liter		
3	Cleaning of interceptor (pumping out waste oil)		
4	Cleaning of oil spill – per square meter (optional)		
	TOTAL (VEP)		
	VAT 9%		
	TOTAL (VIP)		

Notes:

- 1. All Sub-contractors to be used for any part of the works are to be declared.
- 2. FEA financial terms are applicable for these works.
- 3. Site inspection is mandatory.