

TENDER NO – MR 13/2017

**PROJECT: SUPPLY TO WESTERN HOMES
LIMITED AT SONAISALI, NADI**

SCHEME: G81-16

Notes:

1. **Bidders to submit copies of FEA training records with current validity. Bids without this will be disqualified.**
2. Safety Plan to be included in tender bid.
3. Safety Report for 2015, 2016 to be submitted with tender.
4. List of Construction projects completed for FEA to be submitted with tender.
5. **Please pay specific attention to Clause 12 under PART C, Contractor Requirements:**
“Electric Power Lineman/ Line Mechanic/ Line Worker – Contractor shall ensure that the Construction Team comprises a minimum of five personnel, at least one of whom shall be a certified Electric Power Lineman/ Line Mechanic/ Line Worker. The remaining team members shall comprise of registered Trainee Line Workers/ Trainee Linemen/ Trainee Line Mechanic working on the project on a full time basis. Records of these personnel shall be submitted with the bid.
Contractors unable to submit positive proof (Certificates) that they meet this key requirement shall not be considered.
6. **Please pay specific attention to Clause 24 under PART C, Contractor Requirements:**
“Transportation of material – The Contractor shall transport all materials from the FEA Depot (exact depot dependent on project location) to worksite, EXCEPT concrete poles, which may be picked up from Humes Depot, or otherwise as specified by FEA.”

Contractor Name/Stamp

FIRST SCHEDULE

A: SPECIAL CONDITIONS OF CONTRACT –

- The works shall comprise the installation of power lines as per attached Drawing No. **A2-04-N54-356-1 and A2 04-N54-356-2**

Please enter unit rates and lump-sum prices in table below.

The total Contract sum for the works shall be \$_____ **VIP.**

Power Line Construction				
SCHEME NO: G81-16 Supply to Western Homes Limited At Sonaisali, Nadi				
UNIT RATES:				
Item No.	Description	Quantity	Unit Rate	Total
1	Install concrete power pole [11m]	2		
2	Install concrete power pole [10.2m]	14		
3	Install ground stay	1		
4	Install 13B dressing	2		
5	Install 11B dressing	8		
6	Install 5B dressing	1		
7	Install 3B dressing	2		
8	Install 2B dressing	2		
9	Install 1A dressing	15		
10	Install 200kVA 11kV/415V 3Ø Pole Mounted Transformer	1		
11	Install 100kVA 11kV/415V 3Ø Pole Mounted Transformer	1		
12	Install 3Ø HV conductor (route length - km)	0.487		
13	Install 3Ø LV conductor (route length - km)	0.989		
LUMP SUM COSTS:				
Item No.	Material Transport Cost	Total		
1	Transportation of materials from FEA Depot/Supplier to site			
Vegetation Management				
Item No.	Vegetation Management	Total		
1	Vegetation Management as required			

- Work schedule

- (a) Latest date for commencement of the works: 7 days from issue of LPO.
- (b) Date of completion of works: 4 weeks from issue of LPO.
- (c) Date of practical completion of the works: 6 weeks from issue of LPO.
- (d) Date for final completion of the works: 6 weeks from issue of LPO.

2. For the purpose of supervising the contract on behalf of the Authority, references in the General Conditions to the Authority shall include the Unit Leader Distribution West or his designated officer. The Project Manager shall be the Unit Leader Distribution West, the Project Engineer shall be the Unit Leader Distribution West, and the Project Supervisor shall be the Construction Coordinator West.

3. Insurance (refer clause 14)

- (a) Contractor's risk \$500,000.
- (b) Public Liability \$500,000.
- (c) Worker's Compensation \$250,000.

The contractor shall indemnify FEA against any claims for liability, injuries, losses, damages etc that may arise during the execution of the works.

4. Liquidated and ascertained damages (refer clause 20):
\$200 per day.

5. Defects Liability period (refer clause 21): 6 months

6. Retention Fund (refer clause 24)

- (a) Limit of retention fund: 10% of contract sum
- (b) Nature of retention fund: cash
- (c) Release of retention fund: Subject to no pending defect, and as per FEA Finance Policy.

B: SECOND SCHEDULE

Specification for Distribution Powerlines installation for Supply to Western Homes Limited At Sonaisali, Nadi.

1.0 General

2. This specification covers the installation of Distribution Power lines for **Supply to Western Homes Limited At Sonaisali, Nadi** as per attached Drawing No. **A2-04-N54-356-1 and A2 04-N54-356-2** under conditions of Contract attached herein.

2.0 Scope of Work

Work involved in this contract is broadly classified into five phases:

- i) Transportation of material
- ii) Vegetation clearing
- iii) Pole dressing, erection stays etc.
- iv) Stringing of conductors
- v) Installation of transformer, earthing etc

2.1 Phase One – Transportation of Material

The first phase comprises of the following works:

Transportation and load of all material to the jobsite from FEA Depot, except for concrete poles which shall be picked up from Humes Depot, and spalls which shall be picked from either the FEA Depot or SCIL Depot after instruction from FEA.

2.2 Phase Two – Vegetation Clearing

The second phase will involve the clearing of vegetation within 30m from the powerlines.

2.3 Phase Three – Pole dressing, erection, stays etc.

This phase of the contract involves the dressing and erection of poles, the installation of stays, Isolators etc.

2.4 Phase Four – Stringing of conductors

This phase involves the stringing of conductors to FEA standards, their binding, sagging etc.

2.5 Phase Five – Installation of Transformer

This phase involves the installation of transformer, earthing, dressing etc. to FEA standards.

Note: **Installation of ABS and Recloser shall be carried out by FEA**

C: CONTRACTOR REQUIREMENTS

General Below is a list of minimum requirements for overhead power line construction contractors:

- 1) **Bid** – Contractor shall submit a firm bid clearly listing unit costs for all items required. Vegetation clearing and Transportation costs shall be submitted as a lump sum.
- 2) **Site Visit** – Contractor shall participate in a site visit (date, time and location as advised by FEA) which is compulsory. Bids from companies who do not participate in the site visit shall be disqualified. Site visits outside the date/time/location specified by FEA will not be entertained.
- 3) **Standards** – All construction work shall be in compliance with FEA Standard Overhead Line Design & Construction Manual. If any instances occur whereby the requirements of this Manual cannot be complied with or where it is desired for a specific reason to depart from them, written permission must first be obtained from the FEA Unit Leader Distribution
- 4) **Materials** – To ensure quality control, all material for the project shall be supplied by FEA. Non-technical items may be supplied by the contractor only if it is specifically stated in the bid document.
- 5) **Safety Record** –bid shall include a brief report on safety performance over the last two years. The report shall include all incidents and accidents.
- 6) **First Aid** – each team on the jobsite must have a full First Aid Kit.
- 7) **Sub-contracting** – Subcontracting shall not be permitted, except where it is specifically stated by the contractor, and only upon approval by FEA. Subcontractors shall be required to fulfil all requirements as if they were the contractor.
- 8) **Scope of works** - Work involved in this contract is broadly classified into the following six phases, and progress payments shall be processed accordingly.
 - i) Vegetation Clearing;
 - ii) Transportation of material;
 - iii) Pole dressing and installation, including stays (scarfing – if specified in bid document);
 - iv) Stringing of conductors, installation of Air Break Switch, Isolators and line dropouts;
 - v) Installation of transformers, earthing, etc; and
 - vi) Labelling of poles.
- 9) **Contact** - Contractor shall have a valid postal address, office phone/fax/e-mail contact. The Principal shall be available by mobile phone at any time.
- 10) **Work Program** - Contractor shall submit a work program before start of project. This shall be part of the contract. Work shall commence within seven (7) days after receiving an official FEA Purchase Order.

- 11) **Ground condition** – Contractors are to note that sub-soil comprises soapstone and could contain other services such as Telecommunication, Water & Sewerage, etc.
- 12) **Electric Power Lineman/ Line Mechanic/ Line Worker** – Contractor shall ensure that the Construction Team comprises a minimum of five personnel, at least one of whom shall be a certified Electric Power Lineman/ Line Mechanic/ Line Worker. The remaining team members shall comprise of registered Trainee Line Workers/ Trainee Linemen/ Trainee Line Mechanic working on the project on a full time basis. Records of these personnel shall be submitted with the bid.
- 13) **Invoicing** – Contractor shall submit details of work completed to allow prompt approval of invoice.
- 14) **Safety Induction** - A Safety induction must be conducted before start of power line construction work.
- 15) **Instruction to Commence Work** - Contractor shall NOT commence work on site unless an “Instruction to Commence Work” has been received from the Project Manager.
- 16) **Signboards** - One signboard (6’X 4’) must be erected at the start of the works and one at the end of the works clearly stating :

DANGER
<p>PROJECT: POWERLINE CONSTRUCTION – [Description of project] Driver please reduce speed. Pedestrians please use other footpath/side of road</p>
<p>CONTRACTOR: Emergency phone contact: _____ POWER LINE CONSTRUCTION WORK.</p>
<p>Please reduce speed. Pedestrians please use other footpath/side of road.</p>
THANKS

The above must be facing traffic entering into the work area.

The reverse face of the signage must state “Work Ends. Thank You”.

- 17) **Accident Reporting** – All accidents and incidents shall be reported immediately to FEA using approved forms available in the FEA Safety Plan Template, or equivalent.
- 18) **Project Updates** - Contractor shall meet with FEA Project Manager, Project Engineer and Project Supervisor on a weekly basis to discuss project progress and bottlenecks. These meetings shall be minuted for records, and circulated to the appropriate stakeholders.
- 19) **Vegetation clearing** – Vegetation clearing shall be in accordance with FEA Vegetation Management Policy. Vegetation, which at a mature height will exceed 2m in height, must be removed. Vegetation within falling distance from the FEA lines must be removed. Vegetation debris shall be disposed off

neatly at a location agreed to by FEA. No debris shall be left by the roadside or blocking drains. Any debris not cleared promptly will be cleared from the site by FEA (or designated agent) at the expense of the contractor.

- 20) **Tidiness** – The Contractor shall maintain the worksite in a neat and tidy condition.
- 21) **Consent for Vegetation clearing** – no vegetation shall be cleared unless specific instruction to do so has been received from the Project Supervisor. Notwithstanding this, the contractor shall inform the tree owner that he is required to clear the tree, and shall obtain the owner’s confirmation that he has given FEA his consent to remove the tree, prior to proceeding with cutting the tree.
- 22) **Fires** – No fires are to be lit at jobsites for the purpose of clearing vegetation or vegetation debris.
- 23) **Village Protocols** – the contractor shall comply with protocols involved in working on land owned by Indigenous Fijians to ensure smooth work progress.
- 24) **Transportation of material** – The Contractor shall transport all materials from the FEA Depot (exact depot dependent on project location) to worksite, EXCEPT concrete poles, which may be picked up from Humes Depot, or otherwise as specified by FEA.
- 25) **Security** - Contractor shall be responsible for the safekeeping of all materials at work site, and will be required to pay for damage and/or loss.
- 26) **Damage to property** – The Contractor shall ensure that there is no damage to roadways, footpaths, drains, water-courses, properties and other services. The Contractor shall make good to the satisfaction to the owner any damage caused by the contractor.
- 27) **Portable signboards** - Portable signboards must be placed as per the FEA Safety Manual along the roads, and must meet minimum FRA requirements.
- 28) **Traffic and Pedestrian Management** – The Contractor shall ensure that there is minimum disruption to the flow of traffic and pedestrian. FEA procedures on Traffic Control and Pedestrian Control shall be diligently exercised. Traffic and pedestrian management shall, as a minimum, meet Fiji Roads Authority standards.
- 29) **Worksite protection** - Bollards/cone must be placed at intervals not exceeding 10m. At critical locations the interval distances shall be reduced to 5m or lower (e.g. 1m) depending on the risks.
- 30) **Barricades** - Open trench/pole-hole is to be barricaded on a full time basis by the Contractor.
- 31) **Jobsite Safety Assessment** - Contractor to carry out Jobsite Safety Assessment daily, and as and when required, and submit these to FEA on a weekly basis.
- 32) **Credit of surplus material** – The contractor shall transport and credit all unused materials to the designated FEA Stores promptly after the completion of each job. Note that the award of new projects may be put on hold until material verification has been completed.
- 33) **Defects Rectification** – The contractor shall rectify all defects within seven (7) days as per the contract.

- 34) **Project completion** – The contractor shall complete work on time as per the contract.
- 35) **Project progress** – If the Contractor fails to proceed with the works with reasonable diligence or suspends the works or refuses to comply with the reasonable direction from FEA by reason of which the works are materially affected and any such default continues for a period of seven (7) days after the issue of written notice, FEA may itself call any other person/company/new contractor to complete the works at the Contractor’s risk and expense.
- 36) **Insurance** – The Contractor will be required to possess valid insurance policies as shown below :

Policy type	Value
Workers Compensation	\$250,000
Public Liability	\$500,000
Contractors All Risk	\$500,000

- 37) **OHS Compliance** - To provide/submit evidence of OHS compliance from the Ministry of Labour
- 38) **Personal Protective Equipment** – Submit a list of personal protective equipment (PPE) available with the contractor.
- 39) **HSE Requirements** – The contractor’s bid shall include all requirements from the FEA HSE Contractor Safety Management System. These will be evaluated by the FEA’s HSE Unit. Bids with incomplete, unacceptable, or without the HSE requirements will not be considered for award. The Contractor must submit the following with their bid :
- i) **Contractor HSE Specification** – it contains 10 clauses which contains the overall HSE requirements and the contractor needs to agree to this.
 - ii) **Contractor HSE Plan** (Document HSE41C04) – The contractor shall fill in each part of the Plan.
 - iii) The Contractor will list down all the plants and equipment to be used in the **Plant & Equipment Register** as well as chemicals in the **Chemical register**.
 - iv) The **JSA & Risk Assessment** form will require the contractor to identify hazards which may not have been adequately addressed in FEA’s existing procedures and outline proposed controls.

D: FEA REQUIREMENT

- FEA Project Supervisor shall obtain Road/footpath opening permits.
- FEA Project Engineer shall obtain clearance from Municipal Council, Telecom Fiji Ltd, Water Supply Department, and Sewerage Department.
- FEA’s HSE Unit shall vet Safety Plan submitted by Contractor and approve after queries clarified by Contractor.
- FEA Project Engineer shall ensure that any FEA underground mains on the jobsite is clearly located, marked and identified to the Contractor.
- FEA Project Engineer shall submit to the Project Manager all necessary approval documentation from Municipal Council, Fiji Roads Authority, Telecom Fiji Ltd, Water Supply Department and Sewerage Department. Upon receipt of these approvals, and the approved Safety Plan, the Project Manager shall issue an “Instruction to Commence Work” to the Contractor.
- FEA Project Supervisor and Project Engineer shall carry out regular site inspections to ensure compliance with HSE requirements, and submit Safety Visit Reports of the visit.
- FEA Project Supervisor and Project Engineer shall issue Non-Conformance Report if required, and follow up for verification of implementation of Action Items arising out of the Non-Conformance Report.

E: PAYMENT SCHEDULE

Payment shall be made as per payment schedule:

Phase	Description	Percentage payment
1	Material Transportation to worksite	15%
2	Vegetation Clearing	5%
3	Pole dressing, erection, stays, ABS etc.	45%
4	Conductor Stringing	15%
5	Transformer installation complete	10%
6	Retention	10% to be released after 6 months pending zero defects.

Submission of Tender

Two (2) hard copies of the tender bids in sealed envelope shall be deposited in the tender box located at the Supply Chain Office at the FEA Head Office, 2 Marlow Street, Suva, Fiji.

Courier charges for delivery of Tender Document must be paid by the bidders.

This tender closes at 4:00 p.m. (16.00hrs Fiji time) on Wednesday 25th January, 2017.

Site Visit: 10am on Tuesday 17th January 2017 at the FEA's Navutu Depot in Lautoka.

Each tender shall be sealed in an envelope with:

The envelope bearing only the following marking:

TENDER No. MR 13/2017

**Construction of Overhead Power Line for the Supply of Western Homes Limited at
Sonaisali, Nadi - SCHEME: S81-16**

The Secretary, Tender Committee
Fiji Electricity Authority
Supply Chain Office
Private Mail Bag, Suva

It must also indicate the name and address of the tenderer on the reverse of the envelope.

All late tenders, unmarked Envelopes and envelopes without bidder's name and address on the reverse on the envelope will be returned to the Tenderers unopened. (Bids via e-mail or fax will not be considered).

The bidders must ensure that their bid is inclusive of all Taxes payable under Fiji Income Tax Act and must have the most current Tax Compliance Certificate.

For further information or clarification please contact our Supply Chain Office on phone (+679) 3224360 or (+679) 9991587.