

PLAN

ITEM	DESCRIPTION	QTY
1	CHANNEL IRON GALVANISHED	2
2	CHANNEL IRON GALVANISHED	2
3	ANGLE IRON GALVANISHED	2
4	ANGLE IRON GALVANISHED	4
5	CHANNEL IRON GALVANISHED	4
6	PLATE MILD STEEL	8
7	BOLT & NUT GALVANISHED ⌀16 X 300	8
8	BOLT & NUT GALVANISHED ⌀20 X 200	8
9	PLATE IRON GALVANISHED	4
10	BOLT & NUT GALVANISHED ⌀16 X 38	4



ELEVATION



SIDE ELEVATION



ITEM (2) CHANNEL 127 X 63 X 6



ITEM (6) PLATE 200 X 50 X 12



ITEM (5) CHANNEL 76 X 38 X 6.78



ITEM (3) ANGEL 75 X 50 X 6



ITEM (9) PLATE 75 X 50 X 6



ITEM (4) ANGEL 75 X50 X 6



ITEM (1) CHANNEL 127 X 63 X 6

No.	REVISION	DATE	BY	CHK	PSD	APP	REFERENCE	DRAWING No.	TITLE
0	THIS ISSUE SUPERSEDES PREVIOUS ISSUE	02.11.12	R R					CAD FILE NAME	C:\PROJECTS\XXXXXXXX.DWG

DRAWN	RAULUORO. R	02.11.12
CHECKED		
CHIEF DRAUGHTSMAN		
ENGINEER		
HEAD OF DEPARTMENT		

FIJI ELECTRICITY AUTHORITY

STANDARD 11KV/415V SUBSTATION
DOUBLE POLE TRANSFOMER
PLATFORM DETAILS

DRAWING NUMBER: A1 | 01 | E30 | 043

SCALE NTS