



8<sup>th</sup> May 2017

Fiji Electricity Authority

Suva

RE: **FIJI ELECTRICITY AUTHORITY**

**SUPPLY OF 10 X 1MW PRIME RATED GENERATOR SETS**


**NOTICE TO TENDERERS (NTT) NO 1**

The following Control Modes should be available as Modes of Operation for the generators that are tendered for;

1. MW Modes for Base Loading
2. Droop Mode for Remote Control of these Generator as they will be controlled from our remote Control Centre. Provision for remote raise and lower of Speed and Voltage should be provided in this Mode of Operation.
3. Asynchronous Mode for Frequency Control.

Tenderers are to acknowledge this Notice to Tenderers No 1 with their tender.

Kind Regards

  
.....

Epeli Malo

Unit Leader Thermal Generation

Fiji Electricity Authority