



POLE SCHEDULE										
POLE Description No. Wood/Con or exist	POLE Length and Strength m/kN	SPAN m	ANGLE OF LINE DEVIATION IN DEG.	POLE TOP Description OR	STAYS				REMARKS	
					GRND	SIDE WALK	FLY	FLY + GRND		
A	EXIST	—	3	Ex+18A+3A					REMOVE TRXF. & INSTALL DOF	
1	CONC	10.2/6	31	25	12A+2A			1		STRING 1 Ø HV & LV
2	CONC	10.2/6	70	16	11A+1A					" "
3	CONC	10.2/6	70	37	12A+2A	1				" "
4	CONC	10.2/6	97	97	3A+13A+3A+3A	2				" "
5	CONC	11.0	80	13	3A+1A+REM	1				INSTALL 5KVA TRXF
6	CONC	10.2/6	80	0	1A					STRING 1 Ø LV ONLY
7	CONC	10.2/6	80	0	1A					" "
8	CONC	10.2/6	80	—	3A	1				" "

FII ELECTRICITY AUTHORITY

7 SUPPLY TO VUNISALU SETTLEMENT

KOROVOU DISTRICT

NAYAWASARA AREA File No. KO01/16

DRAWING NUMBER

A3	04	N75	113
----	----	-----	-----

SCALE 1 : 2500